



Rennsli Corp
 270 N Geneva Rd
 Orem, UT 84057
 Thomas Parish

March 21, 2024
 Job #:RC032124NSL
 Page: 1 of 2

Laboratory Report

Sample ID: **Clear Diesel Sample, 3-7-24**
 Matrix: Diesel Fuel
 Sample Preparation: None
 Results: Sample **Passes** the following values per ASTM D975

Test	Method	Units	Value	ASTM D975 Limits
Visual	ASTM D4176	Pass/Fail	Pass	Pass
Copper Corrosion	ASTM D130 3 hrs @ 50C	Rating, 3 hrs@50 °C	1a	3 maximum
Distillation	ASTM D86	°F	10%: 384	540 - 640
			50%: 478	
			90%: 604	
			Final Boiling Point: 657	
			vol % Residue: 1.0	
			vol % Loss: 0.1	1.5 maximum
Flash Point	ASTM D93	°F	138	126 minimum
API Gravity Density	ASTM D4052	@60°F kg/m ³	38.2 833	
Cloud Point	ASTM D5773	°F	-3.3	6.0 maximum
Pour Point	ASTM D5949	°F	-49.0	-15.0 maximum
Ash Weight	ASTM D482	mass%	0.000	0.010 maximum
Conductivity	ASTM D2624	pS/m	320*	
Cetane Index	ASTM D4737	calculated	48.3	40.0 minimum



Page 2 of 2
 Job #: RC032124NSL
 Sample ID: **Clear Diesel Sample, 3-7-24**

<u>Test</u>	<u>Method</u>	<u>Units</u>	<u>Value</u>	<u>ASTM D975 Limits</u>
Ramsbottom Carbon (on 10% Distillation residue)	ASTM D524	mass%	0.05	0.35 maximum
Aromatics maximum	ASTM D1319	volume %	24.1	35.0
Olefins	ASTM D1319	volume %	0.9	
Sulfur	ASTM D5453	ppm	4.3*	15 maximum
Bottom Sediment and Water	ASTM D1796	volume %	0.00	0.05 maximum
Kinematic Viscosity @40.0C	ASTM D7042	cSt	2.207	1.9 – 4.1
Color	ASTM D1500	Rating	1.0	
Lubricity	ASTM D6079	µm	399	520 maximum

*: Average of two runs for this test

Analysis Performed by: Oswaldo Albornoz

Reviewed by: Julian Tamillos

Peak Petroleum Testing Services, Inc. has prepared this report for the client listed above, and any third parties who might have received this report in error are respectfully asked to return this data to the intended recipient. The data contained on this report may contain privileged client information and may not be used, in any way, by a third party without prior written consent of both the client and Peak Petroleum Testing Services, Inc. Although every effort has been made to obtain the most accurate test data possible, Peak Petroleum Testing Services, Inc. does not guarantee test data results.